visocolor° ECO DEHA

en

Test kit for performing colorimetric tests on diethylhydroxylamine in boiler water

Method:

Measurement of the reduction properties of diethylhydroxylamine for iron(III) ions and colorimetric determination of the iron(II) ions formed

Measurement range:

0.01 - 0.30 mg/l DEHA

Contents of test kit (*refill pack):

sufficient for 125 tests

30 ml DEHA-1*

25 ml DEHA-2*

- 2 screw-plug measuring glasses
- 1 slide comparator
- 1 colour chart
- 1 plastic syringe 5 ml
- 1 instructions for use*

Hazard warning:

This test does not contain any harmful substances which must be specially labelled as hazardous.

Instructions for use:

also refer to the pictogram on the back of the colour chart

- 1. Cool water sample to 20-25 °C if necessary. Turbid samples are to be filtered (membrane filter 0.45 $\mu m,$ Cat. No. 916 50).
- Pour a 5 ml water sample into each of the measuring glasses using the plastic syringe.

Place a measuring glass on position A in the comparator.

Only add the reagent to measuring glass B.

- Add 4 drops of DEHA-1, seal the glass and mix.
 Add 4 drops of DEHA-2, seal the glass and mix.
- 4. Add 4 drops of DEHA-2, seal the glass and mix.
- Open the glass after 10 min and place it on position B in the comparator.
- Slide the comparator until the colours match in the inspection hole on top. Check the measurement reading in the recess on the comparator reed. Mid-values can be estimated.
- After use, rinse out both measuring glasses thoroughly and seal them.

The method can be applied also for the analysis of sea water.

Disposing of the samples:

The used analysis specimens can be flushed down the drain with tap water and channelled off to the local sewage treatment works.

Interferences:

Strictly observe the temperature and reaction time since they strongly influence the color intensity.

Iron(II) ions interfere. This interference can be taken into account when reading the value immediately after addition of reagent DEHA-2 and substracting this value from the result.

Storage:

Store the test kit in a cool (< 25 °C) and dry place.